

## CERTIFICATE OF DESIGN, INSTALLATION AND COMMISSIONING OF A FIRE DETECTION AND ALARM SYSTEM OF GRADE B, C, D, E OR F IN DOMESTIC PREMISES

Original (To the person ordering the work)

DETAILS OF THE CLIENT		Issued in accordance with BS 5839-6 : 2013
Client:	AB1 DEVELOPMENTS LTD	
Address:	EAST PLESTON COURT THE PLESTON SELBORNE, HANTS. GU34 3JQ	

DETAILS OF THE FIRE DETECTION AND ALARM SYSTEM		The system is
Address	COMMUNAL AREA, FOREST GROVE HOUSE 101A LONDON ROAD, COWPLAIN. WATERLOOINE, HANTS, PO8 80X	
Extent of the fire detection and alarm system covered by this certificate	ENTIRE SYSTEM	
	New: <input checked="" type="checkbox"/>	Modification: <input type="checkbox"/>

DESCRIPTION OF SYSTEM GRADE AND SYSTEM CATEGORY		Tick boxes as appropriate										
System grade	<table style="width: 100%; border: none;"> <tr> <td style="text-align: center;">B</td><td style="text-align: center;">N/A</td><td style="text-align: center;">C</td><td style="text-align: center;">N/A</td><td style="text-align: center;">D</td><td style="text-align: center;"><input checked="" type="checkbox"/></td><td style="text-align: center;">E</td><td style="text-align: center;">N/A</td><td style="text-align: center;">F</td><td style="text-align: center;">N/A</td> </tr> </table>		B	N/A	C	N/A	D	<input checked="" type="checkbox"/>	E	N/A	F	N/A
B	N/A	C	N/A	D	<input checked="" type="checkbox"/>	E	N/A	F	N/A			
System category	<table style="width: 100%; border: none;"> <tr> <td style="text-align: center;">LD1</td><td style="text-align: center;">N/A</td><td style="text-align: center;">LD2</td><td style="text-align: center;">N/A</td><td style="text-align: center;">LD3</td><td style="text-align: center;"><input checked="" type="checkbox"/></td><td style="text-align: center;">PD1</td><td style="text-align: center;">N/A</td><td style="text-align: center;">PD2</td><td style="text-align: center;">N/A</td> </tr> </table>		LD1	N/A	LD2	N/A	LD3	<input checked="" type="checkbox"/>	PD1	N/A	PD2	N/A
LD1	N/A	LD2	N/A	LD3	<input checked="" type="checkbox"/>	PD1	N/A	PD2	N/A			

COMMISSIONING		See Note 1	A tick in the box indicates the inspection or test has been performed and the results are <b>satisfactory</b> . N/A indicates an inspection or test is <b>Not Appropriate</b>
Test buttons checked	<input checked="" type="checkbox"/>	Simulated smoke or aerosol test	<input checked="" type="checkbox"/>
All alarm warning devices operate	<input checked="" type="checkbox"/>	Heat test	<input checked="" type="checkbox"/>
Silencing system checked	<input checked="" type="checkbox"/>	Bedroom sound level (Clause 13.2)	<input checked="" type="checkbox"/>
Dedicated circuit(s) provided	<input checked="" type="checkbox"/>	Protective device labelled	<input checked="" type="checkbox"/>
Audible and visual indication of mains failure	<input checked="" type="checkbox"/>	Sound level test instrument used	<input checked="" type="checkbox"/>
		Model and serial No.	0830557
		Serial No. of associated Electrical Installation Certificate or Minor Electrical Installation Works Certificate (See Note 1)	0378398

USER INSTRUCTIONS		Tick boxes to indicate that the written information has been issued to the user	
I/We the undersigned declare that the occupier* of the domestic premises (or owner in the case of a house in multiple occupancy) has been provided with written information about essential aspects of the operation and maintenance of the system, as follows:			
Operation of the system	<input checked="" type="checkbox"/>	Routine testing of the system	<input checked="" type="checkbox"/>
Action to be taken in the event of a fire alarm signal	<input checked="" type="checkbox"/>	Service and maintenance of the system (including intervals at which any batteries should be replaced)	<input checked="" type="checkbox"/>
Avoidance of false alarms and action in the event of a false alarm	<input checked="" type="checkbox"/>	The need to keep clear space around all detectors and manual call points	<input checked="" type="checkbox"/>
Warning that apparent false alarm from carbon monoxide detector may not be false alarm	<input checked="" type="checkbox"/>	Special precautions relevant to any lithium batteries used in the system	<input checked="" type="checkbox"/>
		Checking the system on reoccupation of the dwelling after a vacation etc.	<input checked="" type="checkbox"/>
		The need to avoid contamination of detectors by paint	<input checked="" type="checkbox"/>
		As-fitted drawing	<input checked="" type="checkbox"/>
* In the case of a newly-built property, and where the future occupier is unknown, the User Instructions should be issued to the builder for onward transmission to the purchaser, together with the related electrical safety certificate.			

CERTIFICATION OF DESIGN, INSTALLATION AND COMMISSIONING			
I/We, being the person(s) responsible (as indicated by my/our signature(s) below), for the design, installation, and commissioning of the fire alarm system, particulars of which are set out above, CERTIFY that the said work for which I/we have been responsible complies to the best of my/our knowledge and belief with the recommendations of BS 5839: Part 6 for the system described above, except for the variations, if any, stated below:			
Variations (if any)	NONE		
The extent of liability of the signatory is limited to the work described above as the subject of this certificate.			
For the <b>DESIGN, INSTALLATION AND COMMISSIONING</b> of the system:		This certificate has been reviewed by the Qualified Supervisor:	
Signature	Date	Signature	Date
	3-10-18		3-10-18
Name (CAPITALS)	Name (CAPITALS)		
NEIL DAVIS	NEIL DAVIS		

DETAILS OF THE DOMESTIC INSTALLER		NICEIC Registration No (Essential information)
Trading Title	BRIGHTWAY ELECTRICAL LTD	
Address	48 BURLINGTON ROAD PORTSMOUTH HANTS	
Postcode	PO2 0DP	
	0113720	

**Note 1.** The electrical safety aspects of the fire detection and alarm system must also be certified in accordance with BS 7671: 'Requirements for Electrical Installations' by issuing an electrical safety certificate of a form which meets the requirements of BS 7671, such as a 'Domestic Electrical Installation Certificate' or, where appropriate, a 'Minor Electrical Installation Works Certificate'.

**Note 2.** An instrument complying with BS EN 61672, Class 2, with slow response and A weighting (see Clause 13.2), is suitable for measuring the sound level.

**Note 3.** This certificate may be required by an authority responsible for enforcement of fire safety legislation, such as the building control authority or housing authority. The recipient of this certificate might rely on the certificate as evidence of compliance with legislation. Liability could arise on the part of any organization or person that issues a certificate without due care in ensuring its validity.

Please see the 'Notes for Recipient' on the reverse of this page.